

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 6911-0075:198 Page 1 of 1

CATEGORY: Voice Communication System Control Units

LISTEE: Fire-Lite Alarms, Inc., One Fire-Lite Place, Northford CT 06472-1653
Contact: Brian Reynolds (203) 484-1200

DESIGN: Model FC-25/50DA Distributed Audio Panel. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

FC-SCB	Slave Command Board
FC-MGM	Message Generator Module
FC-PSM2	Power Supply Module
FC-AAM25N	Audio Amplifier Module
FC-XRM70	Vrms Converter Module
FC-LPS	Local Playback Speaker

RATING: 120 VAC, 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings, and UL Inc. Label

APPROVAL: Listed as voice communication systems for use with separately listed compatible fire alarm control units to provide emergency voice evacuation signals.

NOTE: For Alarm Verification Feature, the maximum Retard/Rest/Restart shall be adjusted to 30 seconds or less.

08-28-01



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **APRIL 10, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE AREND, Senior Deputy
Program Manager**